



MINIMUM STARTING TEMPERATURE -20°F OR -30° C
MAXIMUM BALLAST TO LAMP DISTANCE: 10 FEET
INSULATE UNUSED INPUT LEAD FOR 300 VOLTS
INSULATE LAMP LEAD CRIMP FOR 1000 VOLTS
INSTALL IN ACCORDANCE WITH NATIONAL ELECTRICAL CODE